IEC IECEE CB SCHEME

Ref. Certif. No.
CN45047

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product Produit	Air Circuit Breaker
Name and address of the applicant Nom et adresse du demandeur	Zhejiang CHINT Electric Co., Ltd. No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer Nom et adresse du fabricant	Zhejiang CHINT Electric Co., Ltd. No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Nome et adresse de l'usine Note: *When more than one factory, please report on page 2* Note: *Lorsqueily plus d'une usinem, veuillez utilliser la 2ème page*	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	See the Appendix
Trademark (if any) Marque de fabrique (si elle existe)	CHINT
Model / Type Ref. Ref. De type	NA8-2500H
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2ème page)	
A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la	**PUBLICATION** **EDITION** IEC 60947-2:2016(5th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitre partie de ce Certificat	00901-CB2017CQC-078449

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

CQC **CHINA QUALITY CERTIFICATION CENTRE**

Date: Oct.31,2018

Signature: Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
www.cqc.com.cn

CB 0045854

NA8-2500H
Ui: 1000V
Uimp:12kV;
Ue: AC380/400/415V, AC690V
In: 630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A
Over-current release: Electronic
Ics: AC380V/400/415V: Ics=85kA; AC690V: Ics=65kA
Icu: AC380V/400/415V: Icu=85kA; AC690V: Icu=65kA
Icw: AC380V/400/415V: Icw=85kA/1s, Icw=50kA/3s;
AC690V: Icw=65kA/1s, Icw=50kA/3s;
Selectivity category:B;
3P, 4P
IP20(only front)
Auxiliary contact (Body)
4NO4NC, 6NO6NC:
Ith: 6A
AC-15: Ue/Ie: AC230V/1.3A,AC415V/0.75A
DC-13: Ue/Ie: DC110V/0.55A,DC220V/0.27A
Accessories with electronic circuits:
Undervoltage release:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;
Shunt release:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;
Closing electromagnet:
Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

Additional information (if necessary)
Information complémentaire (si nécessaire)

Date: Oct.31,2018

Signature: Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
www.cqc.com.cn